

**COMMERCIAL BUSINESS
BUILDING AND FIRE SAFETY CHECKLIST**

Propane Tanks

Note: Questions regarding these requirements may be directed to:
Jared Johnson, Building Official (435) 734-6618 or
Jim Buchanan, Fire Marshal (435) 723-4071

☒ = O.K. X = Not Needed Blank = Needs Correction To Comply

	No smoking signs within fifteen feet of propane tanks.
	Weeds, grasses, bushes, trash or other combustible materials shall be kept not less than 10 feet from LP tankers.
	LP tanks shall be protected from vehicle damage.